

WT Accuracy Report Sample

Utility's Contact Info

Utility's logo

Test Type

Type of Standard Being Used for the Accuracy Test

VARh or Wh

Overall Average

YOUR LOGO HERE



Utility Name

1234 Electric Avenue
Palm Beach, Florida, G1P0B5, United State
Phone: 418-626-1126
Email: support@utility.com
Website: utility.com

John Doe

john.doe@utility.com
Employee Id 1701



Test date:

Report date:

Serial number:

Tester model:

05-19-2023 8:46 AM

07-27-2023 9:26 AM

23805962

MT-1/WT3

Calibration Standard Used

Manufacturer/Model	S/N	Description	Calibrated
Radian	RD21	503406	10-11-2022

Watt Hour Collected Data

Current	120.0V		240.0V		480.0V	
	Unity	60° Lag	Unity	60° Lag	Unity	60° Lag
1.5 A	-0.002	0.001	-0.002	-0.001	0.000	0.002
3.0 A	0.000	0.003	-0.001	0.001	0.001	0.003
5.0 A	0.002	0.006	0.000	0.002	0.001	0.004
15.0 A	-0.001	0.000	-0.001	-0.002	0.001	0.001
30.0 A	0.001	0.003	0.000	0.000	0.002	0.003
50.0 A	0.002	0.007	0.000	0.003	0.002	0.004
Average	-0.001	0.002	-0.001	0.000	0.001	0.002
Max	0.002	0.007	0.001	0.003	0.002	0.004
Min	-0.005	0.005	-0.004	-0.004	-0.002	-0.001

Overall

AVERAGE	-0.000	+0.001
MAXIMUM	+0.002	+0.007
MINIMUM	-0.005	+0.005

Accuracy specifications

TYPICAL	± 0.020
MAXIMUM	+ 0.050
MINIMUM	- 0.050

Technician ID

Test Specifications

Results

Specifications



PROBEWELL

MAKING FIELD TESTING EASY

Probewell.com